



Lyncourt  
UFSD

Cathryn Marchese <cmarchese@lyncourtschool.org>

## Water Sampling Results

1 message

Kenneth Waldby <KWaldby@ocmboces.org>

Mon, Oct 17, 2016 at 12:27 PM

To: Cathryn Marchese <cmarchese@lyncourtschool.org>

Cc: Mark Taylor <mtaylor@lyncourtschool.org>, David Daignault <DDaignault@ocmboces.org>

Cathy,

I received the sampling results for Lyncourt school from the sampling that took place on 9/16/16. Of the 58 samples taken, three were over 15 ppb which are to be reported to the Onondaga Co. DOH.

1. Sample # L-19: The girls bathroom sink (right) near the coaches office = 16.0 ppb

2. Sample # L-24: Concession stand sink (low) = 55.0 ppb

3. Sample # L-36: 2nd floor Boys bathroom sink (#3 - sink furthest away from the door) = 30.0 ppb

} See extracted  
(3) pages attached.

The recommendation for these three samples is to resample; a first draw and then a 30-second sample for each outlet above. Until the sampling takes place, recommend signage on each of the outlets indicating do not use. If you have any questions, please contact me.

Ken Waldby, CSP  
Safety Officer  
OCM BOCES  
315-952-2338

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-19**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-015A**Collection Date:** 09/16/16 7:25**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	0.016 *	EPA 200.8 mg/L	(E200.2) 09/26/16 22:26

Girls bathroom near coaches office - bathroom sink, right.

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



# Life Science Laboratories, Inc.

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

## Analytical Results

State Certification No: 10248

CLIENT: Life Science Labs-LIMS

Client Sample ID: L-24

Project: 1615462-Lyncourt UFSD

Location: Lead Study

Matrix: PWS

Lab ID: K1609250-018A

Collection Date: 09/16/16 7:33

Date Received: 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS			
Lead	0.055 *	EPA 200.8 mg/L	(E200.2) 09/26/16 22:46

Concession Stand Sink

Qualifiers: \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Client Sample ID:** L-36**Lab ID:** K1609250-028A**Collection Date:** 09/16/16 6:50**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	0.030 *	EPA 200.8 mg/L	(E200.2) 09/27/16 11:24

2<sup>nd</sup> Floor Boys bathroom sink, farthest from door.

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



# Life Science Laboratories, Inc.

C. Marchese  
Lyncourt UFSD  
2707 Court St  
Syracuse, NY 13208 USA

Phone: (315) 455-7571

## Laboratory Analysis Report

Prepared For

(in its entirety)

Lyncourt UFSD

Client Project ID:

Lead Study

LSL Project ID: 1615462

Receive Date/Time: 09/16/16 14:55

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab  
5854 Butternut Drive  
East Syracuse, NY 13057  
Tel. (315) 445-1900  
Fax (315) 445-1104  
NYS DOH ELAP #10248  
PA DEP #68-2556

LSL North Lab  
131 St. Lawrence Avenue  
Waddington, NY 13694  
Tel. (315) 388-4476  
Fax (315) 388-4061  
NYS DOH ELAP #10900

LSL Finger Lakes Lab  
16 N. Main St., PO Box 424  
Wayland, NY 14572  
Tel. (585) 728-3320  
Fax (585) 728-2711  
NYS DOH ELAP #11667

LSL Southern Tier Office  
Cuba, NY  
Tel. (585) 209-4032  
  
LSL MidLakes Office  
Canandaigua, NY  
Tel. (585) 728-3320

Reviewed by:

Date:

9/15/16

David J. Prichard, Director of Tech. Services

A copy of this report was sent to:

Ken Waldby  
OCM BOCES

Page 1 of 2

Date Printed: 10/3/16

# -- LABORATORY ANALYSIS REPORT --

*Lyncourt UFSD Syracuse, NY*

Sample ID: Lead Study LSL Sample ID: 1615462-001  
Location:  
Sampled: 09/16/16 6:45 Sampled By: DD  
Sample Matrix: PWS

Analytical Method	Prep Method	Prep	Analysis	Analyst
Analyte	Result Units	Date	Date & Time	Initials

(1) Lead Study

Number of Samples

58

MT

Please refer to the chain of custody form on the last page of this report for the detailed descriptions of where these samples were taken.

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab

rptC001

Life Science Laboratories, Inc.

Page 2 of 2

Date Printed: 10/3/16

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-1**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-001A**Collection Date:** 09/16/16 6:45**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	< 0.0010	mg/L	09/26/16 21:17

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-2**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-002A**Collection Date:** 09/16/16 6:46**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0013	mg/L	09/26/16 21:21

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-3**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-003A**Collection Date:** 09/16/16 6:46**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0010	mg/L	09/26/16 21:24

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** L-4

**Lab ID:** K1609250-004A  
**Collection Date:** 09/16/16 6:47  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0037	mg/L	09/26/16 21:28

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-5**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-005A**Collection Date:** 09/16/16 6:50**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0014	mg/L	09/26/16 21:32

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-6**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-006A**Collection Date:** 09/16/16 6:55**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	< 0.0010	mg/L	09/26/16 21:36

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** L-7

**Lab ID:** K1609250-007A  
**Collection Date:** 09/16/16 6:56  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0019	mg/L	09/26/16 21:39

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** L-8

**Lab ID:** K1609250-008A  
**Collection Date:** 09/16/16 6:56  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0016	mg/L	09/26/16 21:43

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

Client Sample ID: *L-11*

**Lab ID:** K1609250-009A  
**Collection Date:** 09/16/16 7:06  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	< 0.0010	mg/L	09/26/16 21:55

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-12**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-010A**Collection Date:** 09/16/16 7:07**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	< 0.0010	mg/L	09/26/16 21:59

**Qualifiers:**

\* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

Client Sample ID: *L-13*

**Lab ID:** K1609250-011A  
**Collection Date:** 09/16/16 7:10  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.0015	mg/L	09/26/16 22:03

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-14**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-012A**Collection Date:** 09/16/16 7:13**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0016	mg/L	09/26/16 22:14

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-15**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-013A**Collection Date:** 09/16/16 7:15**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0039	mg/L	09/26/16 22:18

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** L-17

**Lab ID:** K1609250-014A  
**Collection Date:** 09/16/16 7:20  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0023	mg/L	09/26/16 22:22

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** L-19

**Lab ID:** K1609250-015A  
**Collection Date:** 09/16/16 7:25  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.016 *	mg/L	09/26/16 22:26

Girls bathroom near coaches office - bathroom sink, right.

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-20**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-016A**Collection Date:** 09/16/16 7:25**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.012	mg/L	09/26/16 22:30

**Qualifiers:**

\* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-23**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-017A**Collection Date:** 09/16/16 7:31**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0025	mg/L	09/26/16 22:42

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

Client Sample ID: L-24

**Lab ID:** K1609250-018A  
**Collection Date:** 09/16/16 7:33  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
METALS BY ICPMS		EPA 200.8	(E200.2)
Lead	0.055 *	mg/L	09/26/16 22:46

Concession Stand Sink

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** L-25

**Lab ID:** K1609250-019A  
**Collection Date:** 09/16/16 7:36  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0022	mg/L	09/26/16 22:49

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

Client Sample ID: L-26

**Lab ID:** K1609250-020A  
**Collection Date:** 09/16/16 7:38  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0030	mg/L	09/26/16 22:53

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-27**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-021A**Collection Date:** 09/16/16 7:37**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0085	mg/L	09/26/16 22:57

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** L-28

**Lab ID:** K1609250-022A  
**Collection Date:** 09/16/16 7:40  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0028	mg/L	09/26/16 23:01

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** L-31

**Lab ID:** K1609250-023A  
**Collection Date:** 09/16/16 6:44  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.012	mg/L	09/26/16 23:05

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-32**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-024A**Collection Date:** 09/16/16 6:45**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0065	mg/L	09/26/16 23:08

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-33**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-025A**Collection Date:** 09/16/16 6:45**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.010	mg/L	09/26/16 23:12

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** L-34

**Lab ID:** K1609250-026A  
**Collection Date:** 09/16/16 6:48  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0084	mg/L	09/26/16 23:16

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** L-35

**Lab ID:** K1609250-027A  
**Collection Date:** 09/16/16 6:49  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0055	mg/L	09/27/16 11:20

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

Client Sample ID: L-36

**Lab ID:** K1609250-028A  
**Collection Date:** 09/16/16 6:50  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.030 *	mg/L	09/27/16 11:24

2<sup>nd</sup> Floor Boys bathroom sink, farthest from door.

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-37**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-029A**Collection Date:** 09/16/16 6:53**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0070	mg/L	09/27/16 11:28

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-38**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-030A**Collection Date:** 09/16/16 6:55**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.010	mg/L	09/27/16 11:31

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-40**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-031A**Collection Date:** 09/16/16 7:02**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	0.0016	EPA 200.8 mg/L	(E200.2) 09/27/16 11:35

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-41**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-032A**Collection Date:** 09/16/16 7:04**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	0.0018	EPA 200.8 mg/L	(E200.2) 09/27/16 11:46

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-42**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-033A**Collection Date:** 09/16/16 7:05**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0014	mg/L	09/27/16 11:50

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-43**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-034A**Collection Date:** 09/16/16 7:07**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0015	mg/L	09/27/16 12:02

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-45**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-035A**Collection Date:** 09/16/16 7:11**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0027	mg/L	09/27/16 12:06

**Qualifiers:**

\* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-46**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-036A**Collection Date:** 09/16/16 7:12**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0037	mg/L	09/27/16 12:10

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-47**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-037A**Collection Date:** 09/16/16 7:13**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	0.0033	EPA 200.8 mg/L	(E200.2) 09/27/16 12:14

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-48**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-038A**Collection Date:** 09/16/16 7:14**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0027	mg/L	09/27/16 12:17

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

Client Sample ID: L-49

**Lab ID:** K1609250-039A  
**Collection Date:** 09/16/16 7:15  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0028	mg/L	09/27/16 12:21

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-50**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-040A**Collection Date:** 09/16/16 7:16**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0047	mg/L	09/27/16 12:25

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** L-51

**Lab ID:** K1609250-041A  
**Collection Date:** 09/16/16 7:17  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0061	mg/L	09/27/16 12:29

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-52**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-042A**Collection Date:** 09/16/16 7:18**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0076	mg/L	09/27/16 12:32

**Qualifiers:**

\* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-53**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-043A**Collection Date:** 09/16/16 7:18**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0015	mg/L	09/27/16 12:36

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

Client Sample ID: L-58

**Lab ID:** K1609250-044A  
**Collection Date:** 09/16/16 7:35  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0011	mg/L	09/27/16 12:48

**Qualifiers:** \* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-59**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-045A**Collection Date:** 09/16/16 7:36**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	0.0031	EPA 200.8 mg/L	(E200.2) 09/27/16 12:52

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-60**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-046A**Collection Date:** 09/16/16 7:37**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0063	mg/L	09/27/16 12:56

**Qualifiers:**

\* Value may exceed the Acceptable Level  
E Value exceeds the instrument calibration range  
J Analyte detected below the PQL  
P Prim./Conf. column %D or RPD exceeds limit

B Analyte detected in the associated Method Blank  
H Holding times for preparation or analysis exceeded  
ND Not Detected at the Practical Quantitation Limit (PQL)  
S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-61**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Lab ID:** K1609250-047A**Matrix:** PWS**Collection Date:** 09/16/16 7:38**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0033	mg/L	09/27/16 13:00

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-62**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-048A**Collection Date:** 09/16/16 7:46**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	< 0.0010	mg/L	09/27/16 13:03

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-63**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-049A**Collection Date:** 09/16/16 7:46**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0027	mg/L	09/27/16 13:07

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-64**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-050A**Collection Date:** 09/16/16 7:47**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0033	mg/L	09/27/16 13:11

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

Client Sample ID: L-29

**Lab ID:** K1609250-051A  
**Collection Date:** 09/16/16 7:54  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>			
Lead	0.0067	EPA 200.8 mg/L	(E200.2) 09/27/16 13:24

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

Client Sample ID: L-30

**Lab ID:** K1609250-052A  
**Collection Date:** 09/16/16 7:55  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0027	mg/L	09/27/16 13:44

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-66**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-053A**Collection Date:** 09/16/16 7:46**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0038	mg/L	09/27/16 13:48

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-67**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-054A**Collection Date:** 09/16/16 7:47**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0065	mg/L	09/27/16 13:51

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-68**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Matrix:** PWS**Lab ID:** K1609250-055A**Collection Date:** 09/16/16 7:49**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0016	mg/L	09/27/16 13:55

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** L-69

**Lab ID:** K1609250-056A  
**Collection Date:** 09/16/16 7:50  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0091	mg/L	09/27/16 13:59

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse , NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS**Client Sample ID:** L-70**Project:** 1615462-Lyncourt UFSD**Location:** Lead Study**Lab ID:** K1609250-057A**Matrix:** PWS**Collection Date:** 09/16/16 7:53**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0019	mg/L	09/27/16 14:03

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits

**Life Science Laboratories, Inc.**

5854 Butternut Drive

East Syracuse, NY 13057

(315) 445-1900

**Analytical Results**

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** 1615462-Lyncourt UFSD  
**Location:** Lead Study  
**Matrix:** PWS

**Client Sample ID:** L-71

**Lab ID:** K1609250-058A  
**Collection Date:** 09/16/16 7:54  
**Date Received:** 09/16/16 14:53

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8</b>	<b>(E200.2)</b>
Lead	0.0021	mg/L	09/27/16 14:06

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



Client: Lyncant UFSD

Address: 2707 Court Street

Syracuse NY

# Chain of Custody Record

1615462

Invoiced Government

LSL Project #:

G. Marchese @ Lyncant UFSD

Client's Site I.D.:

K1609210

Containers

Client's Project I.D.:

K1609210  
PCM boces.org

## Authorization:

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type	Matrix	Preserv. Added	Containers # size/type	Analyses	Free Cl (mg/L)	Pres. Check
L-01-001	BR near Art-Rm G-2	9-16-16	6:45	X	PW	HNO3	1 250 ml	Pb		22
L-02-002	Art-Rm G-2 High Sink		6:46				1			
L-03-003	Art-Rm G-2 Low Sink		6:46				1			
L-04-004	Art-Rm G-2 Bathrm		6:47				1			
L-05-005	Art-Rm G-1 Sink		6:50				1			
L-06-006	Homer-Grass G-2 K-1 Sink		6:55				1			
L-07-007	Homer-Grass G-2 K-2 Sink		6:55				1			
L-08-008	Homer-Grass G-2 K-3 Sink		6:56				1			
L-09-009	PE OFFICE G-9 K-4 K-5 K-6		7:00				1			
L-10-010	BR Sink G-9 K-4 K-5 K-6		7:04				1			
L-11-011	BR outside CAFE Sink LFT		7:06				1			
L-12-012	BR outside CAFE Sink RFT		7:07				1			
L-13-013	CR-A-1 Sink		7:10				1			
L-14-014	BATHRM Sink NEAR P-3		7:13	↓			1			

Notes and Hazard identifications: L-10 \* Sample time taken from sample bottle, as per Ken w. time on the bottle is correct. RD 9/19/16

Custody Transfers	
Sampled and Relinquished By:	Date
Print Name: <u>David Dignas</u>	<u>9/16/16</u>
Signature: <u>[Signature]</u>	Time
	<u>8:10 am</u>
Received By:	
Relinquished By: <u>David Dignas</u>	Received By: <u>Keller</u>
Relinquished By: <u>[Signature]</u>	Received for Lab By: <u>Lyn Van der Vliet</u>
	9/16/16 19:53
Shipment Method: <u>20°C</u>	

Samples L-09 > Void

Phone # (315) 445-1900

Telefax # (315) 445-1104

LSL Project # 200

Client: Lyndant UFSD

Address: 2707 Court Street

Phone #

Fax #

Syracuse NY

Contact Person: G. Marchese @  
Lyncontichoo.org  
Client's Site I.D.: Kweelby @  
QCM baces.org

Client's Sample Identifications		Authorization:		Client's Project I.D.:	
LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type	grab comp.
L-15 <sup>013</sup>	CR A-2 Sink	9-16-16	7:15	X	
L-16	Boys BR Sink		7:17		
L-17 <sup>014</sup>	Boys BR Sink		7:20		
L-18	Boys BR Sink		7:20		
L-19 <sup>015</sup>	Girls BR Sink		7:25		
*L-20 <sup>016</sup>	Girls BR Sink		7:25		
L-21	Boys BR Sink		7:29		
L-22	Boys BR Sink		7:30		
L-23 <sup>017</sup>	Boys BR Sink		7:31		
L-24 <sup>018</sup>	Boys BR Sink		7:33		
L-25 <sup>019</sup>	Boys BR Sink		7:36		
L-26 <sup>020</sup>	Boys BR Sink		7:38		
L-27 <sup>021</sup>	Boys BR Sink		7:39		
L-28 <sup>022</sup>	Boys BR Sink		7:40		

Notes and Hazard identifications:

Samples L-16 } Void  
L-21 }  
L-22 }

Custody Transfers

Print Name: David Dargatz

Signature: [Signature]

Received By:

Received By: [Signature]

Received for Lab By:

Received for Lab By: [Signature]

St. Vincent Method:

20°C

Date: 9/16/16  
Time: 8:00 am

Date: 9/16/16  
Time: 8:00

Date: 9/16/16  
Time: 11:53

# Chain of Custody Record

1615462

Invoiced Government

200

Contact Person: G. Marchese @ Lyncourt UFSD

LSL Project #

Client's Site I.D.:

Kwaddy @ PCM boxes.org

Client's Project I.D.:

## Authorization:

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type	Matrix	Preserv. Added	Containers # size/type	Analyses	Free Cl (mg/L)	Pres. Check
L-31083	2nd Floor G-2 BR1	9-16-16	6:44	X	PW	HNO3	1 250 ml	Pb		12
L-32034	2nd F G-2 BR2		6:45				1			
L-33035	↓ G-2 BR #3		6:45				1			
L-34036	2nd Floor BR #1		6:49				1			
L-35097	↓ #2		6:49				1			
L-36038	↓ #2		6:50				1			
L-37039	Room 2-5 sink		6:53				1			
L-38040	Library BR		6:55				1			
L-39041	Custodial Closet		6:57				1			
L-40042	2nd Grounding GBR #1		6:57				1			
L-41043	#2		6:57				1			
L-42044	Boys BR #1		6:57				1			
L-43045	↓ BR #2		6:57				1			
L-44046	Cust. Classroom		6:59	✓			1			

## Notes and Hazard identifications:

Samples L-39 } void  
L-44 }

## Custody Transfers

Sampled and Relinquished By:

Print Name: Ken Waddy

Signature:

Received By:

Received By:

Received for Lab By:

Shipment Method:

20°C

Date

Time

9/16/16

14:53

9/16/16

14:53



Client:	Phone # (315) 445-1900	Telefax # (315) 445-1104	Contact Person:	LSL Project #:
Address:	Lyncourt VP&SD 2007 Court Street Syracuse NY		C. Marchese @ Lyncourtvp&sd.org	
			Kivashky @ ocmboces.org	Client's Site I.D.:

**Authorization:**

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
L- 59 <del>045</del>	Wine P/B BR 82	9-15-16	0736	X		PW	HNO <sub>3</sub>	1	250 ml	Pb		22
L- 60 <del>046</del>	BR 83		0737					1				22
L- 61 <del>047</del>	BR 84		0738					1				22
L- 62 <del>048</del>	Nurs BR		0740					1				22
L- 63 <del>049</del>	Nurse Examplur		0746					1				22
L- 64 <del>050</del>	Nurs 36 Pipe		0747					1				22
L- 65 <del>051</del>	Ladies Staff BR		0748					1				22
L- 66 <del>052</del>								1				22
L- 29 <del>053</del>	Room 1-5 Sink		0754					1				22
L- 30 <del>054</del>	Room 1-5 BR		0755					1				22
L- 31 <del>055</del>								1				22
L- 32 <del>056</del>								1				22
L- 33 <del>057</del>								1				22
L- 34 <del>058</del>								1				22

**Notes and Hazard identifications:**

## Custody Transfers

**Sampled and Relinquished By:**

Print Name: Kar Nishan Signature: Kar Nishan

Received By:Received By:Received for Lab By:

### Shipment Method:

202



