



December 09, 2025

Dana Darling
Lyncourt Union Free School District
2707 Court Street
Syracuse, NY 13208

RE: Project: LYNLCOURT UNION FREE SD
Pace Project No.: 70393103

Dear Dana Darling:

Enclosed are the analytical results for sample(s) received by the laboratory on November 20, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads 'Alexandria Correa'.

Alexandria Correa
alexandria.correa@pacelabs.com
516-370-6000
Project Manager

Enclosures

cc: OCM BOCES Safety Services, OCM BOCES
David Shaw, Lyncourt Union Free School District



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-01		Lab ID: 70393103001		Collected: 11/07/25 05:05		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 12:58	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-02		Lab ID: 70393103002		Collected: 11/07/25 05:06		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:01	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-03		Lab ID: 70393103003		Collected: 11/07/25 05:07		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:03	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD
Pace Project No.: 70393103

Sample: LYNCSO-04		Lab ID: 70393103004		Collected: 11/07/25 05:08		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:06	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-05		Lab ID: 70393103005		Collected: 11/07/25 05:08		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:08	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-06		Lab ID: 70393103006		Collected: 11/07/25 05:09		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1	12/08/25 07:29	12/08/25 17:43	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD
Pace Project No.: 70393103

Sample: LYNCSO-07		Lab ID: 70393103007		Collected: 11/07/25 05:13		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:09	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-08		Lab ID: 70393103008		Collected: 11/07/25 05:14		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:10	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-09		Lab ID: 70393103009		Collected: 11/07/25 05:16		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:12	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD
Pace Project No.: 70393103

Sample: LYNCSO-10		Lab ID: 70393103010		Collected: 11/07/25 05:17		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:13	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: LYNCOURT UNION FREE SD
Pace Project No.: 70393103

Sample: LYNCSD-11		Lab ID: 70393103011		Collected: 11/07/25 05:19		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:14	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-12		Lab ID: 70393103012		Collected: 11/07/25 05:20		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:15	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD
Pace Project No.: 70393103

Sample: LYNCSO-13		Lab ID: 70393103013		Collected: 11/07/25 05:26		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:17	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD
Pace Project No.: 70393103

Sample: LYNCSO-14		Lab ID: 70393103014		Collected: 11/07/25 05:27		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:18	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-15		Lab ID: 70393103015		Collected: 11/07/25 05:29		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:22	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSD-16		Lab ID: 70393103016		Collected: 11/07/25 05:30		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		12/04/25 13:23	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-17		Lab ID: 70393103017		Collected: 11/07/25 05:32		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:24	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-18		Lab ID: 70393103018		Collected: 11/07/25 05:34		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:25	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD
Pace Project No.: 70393103

Sample: LYNCSO-19		Lab ID: 70393103019		Collected: 11/07/25 05:35		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:27	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-20		Lab ID: 70393103020		Collected: 11/07/25 05:36		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:28	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-21		Lab ID: 70393103021		Collected: 11/07/25 05:40		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:32	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-22		Lab ID: 70393103022		Collected: 11/07/25 05:42		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:38	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD
Pace Project No.: 70393103

Sample: LYNCSO-23		Lab ID: 70393103023		Collected: 11/07/25 05:45		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:42	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-24		Lab ID: 70393103024		Collected: 11/07/25 05:46		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:43	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNCCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-25		Lab ID: 70393103025		Collected: 11/07/25 05:49		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:44	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNCCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-26		Lab ID: 70393103026		Collected: 11/07/25 05:50		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:45	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-27		Lab ID: 70393103027		Collected: 11/07/25 05:52		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:47	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-28		Lab ID: 70393103028		Collected: 11/07/25 05:53		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:48	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD
Pace Project No.: 70393103

Sample: LYNCSO-29		Lab ID: 70393103029		Collected: 11/07/25 05:55		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:52	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-30		Lab ID: 70393103030		Collected: 11/07/25 05:58		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:53	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-31		Lab ID: 70393103031		Collected: 11/07/25 05:59		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:54	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD
Pace Project No.: 70393103

Sample: LYNCSO-32		Lab ID: 70393103032		Collected: 11/07/25 06:01		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:55	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-33		Lab ID: 70393103033		Collected: 11/07/25 06:03		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:57	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNCCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-34		Lab ID: 70393103034		Collected: 11/07/25 06:04		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:58	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-35		Lab ID: 70393103035		Collected: 11/07/25 06:05		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 13:59	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD
Pace Project No.: 70393103

Sample: LYNCSO-36		Lab ID: 70393103036		Collected: 11/07/25 06:08		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Melville							
Lead	2.0	ug/L	1.0	1		12/04/25 14:01	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-37		Lab ID: 70393103037		Collected: 11/07/25 06:11		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 14:02	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYN COURT UNION FREE SD
Pace Project No.: 70393103

Sample: LYNCS D-38		Lab ID: 70393103038		Collected: 11/07/25 06:12		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	34.1	ug/L	1.0	1	12/08/25 07:29	12/08/25 17:44	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD
Pace Project No.: 70393103

Sample: LYNCSO-39		Lab ID: 70393103039		Collected: 11/07/25 06:13		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.3	ug/L	1.0	1		12/04/25 14:03	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-40		Lab ID: 70393103040		Collected: 11/07/25 06:14		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	27.5	ug/L	1.0	1	12/08/25 07:29	12/08/25 17:45	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-41		Lab ID: 70393103041		Collected: 11/07/25 06:14		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.5	ug/L	1.0	1		12/04/25 14:07	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

Sample: LYNCSO-42		Lab ID: 70393103042		Collected: 11/07/25 06:15		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	16.8	ug/L	1.0	1	12/08/25 07:29	12/08/25 17:46	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: LYNLCOURT UNION FREE SD
Pace Project No.: 70393103

Sample: LYNCSO-43		Lab ID: 70393103043		Collected: 11/07/25 06:18		Received: 11/20/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/04/25 14:08	7439-92-1		

REPORT OF LABORATORY ANALYSIS



QUALITY CONTROL DATA

Project: LYNCOURT UNION FREE SD

Pace Project No.: 70393103

QC Batch:	431099	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70393103001, 70393103002, 70393103003, 70393103004, 70393103005, 70393103007, 70393103008, 70393103009, 70393103010, 70393103011, 70393103012, 70393103013, 70393103014, 70393103015, 70393103016, 70393103017, 70393103018, 70393103019, 70393103020		

METHOD BLANK:	2307440	Matrix:	Water
Associated Lab Samples:	70393103001, 70393103002, 70393103003, 70393103004, 70393103005, 70393103007, 70393103008, 70393103009, 70393103010, 70393103011, 70393103012, 70393103013, 70393103014, 70393103015, 70393103016, 70393103017, 70393103018, 70393103019, 70393103020		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/04/25 12:52	

LABORATORY CONTROL SAMPLE:	2307441					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.4	93	85-115	

MATRIX SPIKE SAMPLE:		2307443					
		70392947001	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	48.1	96	70-130	

MATRIX SPIKE SAMPLE:		2307445					
		70393103001	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	48.9	97	70-130	

SAMPLE DUPLICATE:	2307442				
Parameter	Units	70392947001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE:	2307444				
Parameter	Units	70393103001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: LYN COURT UNION FREE SD

Pace Project No.: 70393103

QC Batch:	431100	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70393103021, 70393103022, 70393103023, 70393103024, 70393103025, 70393103026, 70393103027, 70393103028, 70393103029, 70393103030, 70393103031, 70393103032, 70393103033, 70393103034, 70393103035, 70393103036, 70393103037, 70393103039, 70393103041, 70393103043		

METHOD BLANK:	2307448	Matrix:	Water
Associated Lab Samples:	70393103021, 70393103022, 70393103023, 70393103024, 70393103025, 70393103026, 70393103027, 70393103028, 70393103029, 70393103030, 70393103031, 70393103032, 70393103033, 70393103034, 70393103035, 70393103036, 70393103037, 70393103039, 70393103041, 70393103043		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/04/25 13:29	

LABORATORY CONTROL SAMPLE:	2307449					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	45.7	91	85-115	

MATRIX SPIKE SAMPLE:		2307451					
		70393103021	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	48.2	96	70-130	

MATRIX SPIKE SAMPLE:		2307453					
		70393103022	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	48.2	96	70-130	

SAMPLE DUPLICATE:	2307450				
Parameter	Units	70393103021 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE:	2307452				
Parameter	Units	70393103022 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

QC Batch: 431455

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET Drinking Water

Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70393103006, 70393103038, 70393103040, 70393103042

METHOD BLANK: 2310261

Matrix: Water

Associated Lab Samples: 70393103006, 70393103038, 70393103040, 70393103042

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/08/25 17:38	

LABORATORY CONTROL SAMPLE: 2310262

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.0	102	85-115	

MATRIX SPIKE SAMPLE: 2310266

Parameter	Units	70393989008 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	47.1	50	109	124	70-130	

MATRIX SPIKE SAMPLE: 2310513

Parameter	Units	70393989009 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	7.6	50	61.2	107	70-130	

SAMPLE DUPLICATE: 2310265

Parameter	Units	70393989008 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	47.1	47.7	1	

SAMPLE DUPLICATE: 2310512

Parameter	Units	70393989009 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	7.6	7.5	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: LYNLCOURT UNION FREE SD

Pace Project No.: 70393103

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

BATCH QUALIFIERS

Batch: 431515

[1] The post digestion spike for sample 70393989008 (PDS 2310535) exceeded acceptance criteria for Copper and Silver.

[2] The post digestion spike for sample 70393898009 (PDS 2310537) exceeded acceptance criteria for Copper.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: LYNCCOURT UNION FREE SD

Pace Project No.: 70393103

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70393103006	LYNCSD-06	EPA 200.8	431455	EPA 200.8	431515
70393103038	LYNCSD-38	EPA 200.8	431455	EPA 200.8	431515
70393103040	LYNCSD-40	EPA 200.8	431455	EPA 200.8	431515
70393103042	LYNCSD-42	EPA 200.8	431455	EPA 200.8	431515
70393103001	LYNCSD-01	EPA 200.8	431099		
70393103002	LYNCSD-02	EPA 200.8	431099		
70393103003	LYNCSD-03	EPA 200.8	431099		
70393103004	LYNCSD-04	EPA 200.8	431099		
70393103005	LYNCSD-05	EPA 200.8	431099		
70393103007	LYNCSD-07	EPA 200.8	431099		
70393103008	LYNCSD-08	EPA 200.8	431099		
70393103009	LYNCSD-09	EPA 200.8	431099		
70393103010	LYNCSD-10	EPA 200.8	431099		
70393103011	LYNCSD-11	EPA 200.8	431099		
70393103012	LYNCSD-12	EPA 200.8	431099		
70393103013	LYNCSD-13	EPA 200.8	431099		
70393103014	LYNCSD-14	EPA 200.8	431099		
70393103015	LYNCSD-15	EPA 200.8	431099		
70393103016	LYNCSD-16	EPA 200.8	431099		
70393103017	LYNCSD-17	EPA 200.8	431099		
70393103018	LYNCSD-18	EPA 200.8	431099		
70393103019	LYNCSD-19	EPA 200.8	431099		
70393103020	LYNCSD-20	EPA 200.8	431099		
70393103021	LYNCSD-21	EPA 200.8	431100		
70393103022	LYNCSD-22	EPA 200.8	431100		
70393103023	LYNCSD-23	EPA 200.8	431100		
70393103024	LYNCSD-24	EPA 200.8	431100		
70393103025	LYNCSD-25	EPA 200.8	431100		
70393103026	LYNCSD-26	EPA 200.8	431100		
70393103027	LYNCSD-27	EPA 200.8	431100		
70393103028	LYNCSD-28	EPA 200.8	431100		
70393103029	LYNCSD-29	EPA 200.8	431100		
70393103030	LYNCSD-30	EPA 200.8	431100		
70393103031	LYNCSD-31	EPA 200.8	431100		
70393103032	LYNCSD-32	EPA 200.8	431100		
70393103033	LYNCSD-33	EPA 200.8	431100		
70393103034	LYNCSD-34	EPA 200.8	431100		
70393103035	LYNCSD-35	EPA 200.8	431100		
70393103036	LYNCSD-36	EPA 200.8	431100		
70393103037	LYNCSD-37	EPA 200.8	431100		
70393103039	LYNCSD-39	EPA 200.8	431100		
70393103041	LYNCSD-41	EPA 200.8	431100		
70393103043	LYNCSD-43	EPA 200.8	431100		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Pace® Location Requested (City/State):
Pace Analytical Long Island NY
575 Broad Hollow Rd, Melville, NY 11747

Company Name: Lyncourt Union Free School District
Street Address: 2707 Court Street
Syracuse, NY 13208

Customer Project #: Lyncourt Union Free School District

Site Collection Info/Facility ID (as applicable):

Contact/Report To: Dana Darling
Phone #: ddarling@lynccourtschool.org
E-Mail:
Cc E-Mail:

Invoice To:

Invoice E-Mail:

Purchase Order # (if applicable):

Quote #:

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY - Attach Workorder/Login Label Here

WO#: 70393103
70393103

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) Encore, (8) TerraCore, (9) Other

***Preservative Types: (1) None, (2) HNO₃, (3) H₂SO₄, (4) HCl, (5) NaOH, (6) Zn-Acetate, (7) H₂SO₄, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) NaOH, (11) Other

Analysis Requested

Lab Use Only
Proj. Mgr: Alexandria Correa
ActNum / Client ID:
Table #:
Profile / Template:
Prelog / Bottle Ord. ID:

Time Zone Collected: [] AK [] PT [] MT [] CT [X] ET
Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead In School DW
Rush (Pre-approval required):
[] 2 Day [] 3 day [] 5 day [] Other
Date Results Requested: Standard 30 business day
Field Filtered (if applicable): [] Yes [] No
Analysis:
* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start)		Composite End		Res. CL2	Number & Type of Containers		200.8 Drinking Water (Pb only)	Preservation non-conformance identified for sample
			Date	Time	Date	Time		Plastic	Glass		
LYNCSD- 01	DW	G	11/7/2025	505				1		X	
LYNCSD- 02	DW	G	11/7/2025	506				1		X	
LYNCSD- 03	DW	G	11/7/2025	507				1		X	
LYNCSD- 04	DW	G	11/7/2025	508				1		X	
LYNCSD- 05	DW	G	11/7/2025	509				1		X	
LYNCSD- 06	DW	G	11/7/2025	510				1		X	
LYNCSD- 07	DW	G	11/7/2025	513				1		X	
LYNCSD- 08	DW	G	11/7/2025	514				1		X	
LYNCSD- 09	DW	G	11/7/2025	516				1		X	
LYNCSD- 10	DW	G	11/7/2025	517				1		X	

Customer Remarks / Special Conditions / Possible Hazards:

Collected By:

Printed Name: Skylar Schwed
Signature:

Additional Instructions from Pace®:

Coolers: 7421 Correction Temp (°C): 17.9 Corrected Temp (°C) 18.0

Tracking Number: 1430

Date/Time: 11/19/25 1430

Delivered by: [] In-Person [] Courier

Date/Time: 11/19/25 1430

Date/Time: 11/19/25 1430

Page: of

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at <https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/>

ENV-FRM-CORQ-0019_v01_082123 ©

CHAIN-OF-CUSTODY Analytical Request Document

Chain-of-Custody Is a LEGAL DOCUMENT - Complete all relevant fields

Pace® Location Requested (City/State):
Pace Analytical Long Island NY
575 Broad Hollow Rd, Melville, NY 11747

Company Name: Lyncourt Union Free School District
Street Address: 2707 Court Street
Syracuse, NY 13208

Contact/Report To:
Phone #:
E-Mail:
Cc E-Mail:

Customer Project #: **Lyncourt Union Free School District**
Project Name:

Site Collection Info/Facility ID (as applicable):

Time Zone Collected:	☐ AK	☐ PT	☐ MT	☐ CT	☒ ET	County / State origin of sample(s):	New York
Data Deliverables:	Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW						

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

	Rush (Pre-approval required):	DW PWSID # or WW Permit # as applicable:
--	--------------------------------------	--

Date Results Requested: Standard 10 business day

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OI), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Coh	Collected (or Composite Start)	Composite End	Res. #	Number & Type of Containers
--------------------	----------	---------------	-----------------------------------	---------------	-----------	--------------------------------

INVOICE NO.	DATE	TIME	DATE	TIME	GLASS	PLASTIC
1	11/7/2025	5:01				1

[illegible]

LYNCSD-11	DW	G	11/1/2025	320	1
-----------	----	---	-----------	-----	---

LYNCSD-13	DW	G	11/7/2025	526	1
-----------	----	---	-----------	-----	---

LYNCSD- 14	DW	G	11/7/2025	S27	1
------------	----	---	-----------	-----	---

LYNCSD- 15	DW	G	11/7/2025	524	1
------------	----	---	-----------	-----	---

LYNCSD- 6	DW	G	11/7/2025	S30	1
-----------	----	---	-----------	-----	---

LYNCSD- 17	DW	G	11/7/2025	532	1
------------	----	---	-----------	-----	---

[illegible]

Customer Remarks / Special Conditions / Possible Hazards:

Lead

Collected By:
Printed Name: Skylar Schwed
Signature:

ReInghausted by/Company; (Signature)	Date/Time:
--------------------------------------	------------

15	117010	
----	--------	--

agreed

52

Inquired by/Company: (signature)

Received by Company: (Signature)

1001

11

22/03/2020

Received by/Company. (Signature)

Al Coolers:	Thermometer No. 2	Correction Factor (C):	Obs. Temp. (C)	Corrected Temp. (C)

Al Coolers:	Thermometer No. 2	Correction Factor (C):	Obs. Temp. (C)	Corrected Temp (C)
-------------	-------------------	------------------------	----------------	--------------------

Date/Time: 11/11/2011 10:11	Tracking Number: 1011
-----------------------------	-----------------------

Date/Time: 11/18/2019 3:09 PM Delivered by: [] In-Person [] Courier

Date/Time: 11/10/2011 11:11 AM

Date/Time: _____ Page: _____ of _____

WO#: 70393103

Client Name:

LynCourtUFSD

Project #

PM: ALC

Due Date: 12/08/25

CLIENT: LYNLCOURTUFSD

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other

Tracking #:

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals Intact: ☐ Yes ☐ No Temperature Blank Present: ☐ Yes ☒ No

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☐ None ☐ Other Type of Ice: Wet Blue None

Thermometer Used: TH211 Correction Factor: +0.1 ☐ Samples on ice, cooling process has begun

Cooler Temperature(°C): 17.9 Cooler Temperature Corrected(°C): 18.0 Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil (☒ N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ Yes ☐ No

Did samples originate from a foreign source including Hawaii and Puerto Rico)? ☐ Yes ☐ No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents:

	COMMENTS:
Chain of Custody Present: ☒ Yes ☐ No	1.
Chain of Custody Filled Out: ☒ Yes ☐ No	2.
Chain of Custody Relinquished: ☒ Yes ☐ No	3.
Sampler Name & Signature on COC: ☒ Yes ☐ No ☐ N/A	4.
Samples Arrived within Hold Time: ☒ Yes ☐ No	5.
Short Hold Time Analysis (<72hr): ☐ Yes ☒ No	6.
Rush Turn Around Time Requested: ☐ Yes ☒ No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) ☒ Yes ☐ No	8.
Correct Containers Used: ☒ Yes ☐ No	9.
-Pace Containers Used: ☒ Yes ☐ No	10.
Containers Intact: ☒ Yes ☐ No	11.
Filtered volume received for Dissolved tests ☐ Yes ☐ No ☒ N/A	Note: if sediment is visible in the dissolved container.
Sample Labels match COC: ☒ Yes ☐ No	12.
-Includes date/time/ID/Analysis Matrix: SL WT OIL OTHER	

Date and Initials of person checking preservation:

All containers needing preservation have been ☒ Yes ☐ No ☐ N/A	13. ☐ HNO ₃ ☐ H ₂ SO ₄ ☐ NaOH ☐ HCl
pH paper Lot # <u>210525</u>	Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, ☒ Yes ☐ No ☐ N/A	
NAOH>12 Cyanide)	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).	
Per Method, VOA pH is checked after analysis	
Samples checked for dechlorination: ☐ Yes ☐ No ☒ N/A	14.
KI starch test strips Lot #	
Residual chlorine strips Lot #	Positive for Res. Chlorine? Y N
SM 4500 CN samples checked for sulf ☐ Yes ☐ No ☒ N/A	15.
Lead Acetate Strips Lot #	Positive for Sulfide? Y N
Headspace in ALK Bottle (>6mm): ☐ Yes ☐ No ☒ N/A	
Headspace in VOA Vials (>6mm): ☐ Yes ☐ No ☒ N/A	16.
Trip Blank Present: ☐ Yes ☐ No ☒ N/A	17.
Trip Blank Custody Seals Present ☐ Yes ☐ No ☒ N/A	

Client Notification/ Resolution:

Field Data Required?

Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.